



CMC

Tension › Control › Integration

Amplifier Instruction Manual

Range: Advance

Type: AO8050


Revision: V1.1

Contents

Contents.....	1
1. General Description	2
2. Installation.....	3
2.1 Selection of Amplifier Location	3
2.2 Mechanical Dimensions.....	3
3. Connections.....	4
3.1 Terminal Layout	4
3.2 Transducer Half Bridge Wiring Configurations	5
3.3 Transducer Full Bridge Wiring Configurations.....	6
4. Setup and Calibration	7
4.1 Device Terminology	7
4.2 Menu Tree	8
4.3 Gain	9
4.4 Determining the Gain.....	9
4.5 Calibration Process	10
4.5.1 Type Selection (Gain).....	10
4.5.2 Mode Selection (STD single channel or dual channel for TLR)	10
4.5.3 Tare the Load Cell Roller	10
4.5.4 Calibrate the Load Cell Roller	12
5. Technical Data	13

1. General Description


The Advance range AO8050 amplifier is an all-digital amplifier designed to meet all requirements of tension sensing within industries that are handling: printing applications, converting, paper, foil, narrow web, labels, ribbon, wire and other weight systems. The Advance range AO805x works with our range of Cleveland Kidder Classic, Ultra and Advance transducers, it also works with all other variants known to us.



The installation and calibration has been simplified due to the internal recognition feature the output automatically adjusts to the load cell input. The internal filters give a steady display output and a balanced output signal, for easier handling of the actual data reading.

2. Installation

2.1 Selection of Amplifier Location




The controller must be installed in a dry, ventilated, non-hazardous, vibration free location. Preferably inside an electrical cabinet and out of reach of the machine operator. The amplifier is designed to be mounted onto a standard 35mm wide DIN rail (EN 50022) inside a larger cabinet. For ease of installation, all the external connections are via plug in screw terminals, and numbered terminals. Wire end ferrules are suggested for good practice.

The supply to the amplifier is +24V DC, fused to a maximum of 2A. The DC zero should be connected to the 0V common line, which in turn is connected to a clean earth point.

The tension transducer(s) must be installed in accordance with the procedures from the transducer handbook. Particularly with regard to the web wrap angle and load line orientation.

Always use screened cable for connecting the transducer. If the cable is extended, the screen must be 'followed through'. The screen should be connected to earth at the amplifier end only. The screen is NOT connected at the transducer end so as to avoid earth loops. display.


2.2 Mechanical Dimensions



3. Connections


3.1 Terminal Layout

The Advance Range AO8050 amplifier is a single channel load cell amplifier with Modbus RS485 RTU it is designed for applications with 1 or 2 semiconductor half bridge load cells and 1 or 2 foil gauge full bridge load cells mounted in parallel to provide a calibrated total tension output. All load cell connection cables are mounted in one 6 pin plug screw terminal. The output alternatives are 1 x 0-10V, 1 x $\pm 10V$ and 1 x 4-20mA.




3.2 Transducer Half Bridge Wiring Configurations


Single half bridge load cell



Two half bridge load cells




Zener Barrier Connections






3.3 Transducer Full Bridge Wiring Configurations

Single full bridge load cell



Two full bridge load cell




4. Setup and Calibration

4.1 Device Terminology

DIAG	Diagnostic
SW. VER	Software version; actual software version
LOADC.	Load Cell
LCTYPE	Load Cell type based on type of gauge
SLC	Strain gauge Load Cell 120 Ω semiconductor resistance
FLC	Foil gauge Load Cell 350 Ω resistance
G1-G128	Gain factor gives a selectable input range
LCMODE	How the Load Cell is connected
STD	Standard gives an average reading if two Load Cells are connected
TLR	Total-Left-Right gives a separate reading on each of two Load Cells connected, so the "Total" average reading, Left-side and Right-side reading are all available
TARE	Zero calibration without tension on the Load Cell
CAL	Calibration; with a known weight giving tension to the Load Cell
UNIT	The selected display and calibration weighing unit
N (kg)	Actual tension displayed in N and the physical calibration weight given in Kg.
N (lbs)	Actual tension displayed in N and the physical calibration weight given in lbs.
Kg	Actual tension displayed in Kg and the physical calibration weight given in Kg.
Lbs	Actual tension displayed in lbs and the physical calibration weight given in lbs.
%	Actual tension displayed in % and the physical calibration weight given in % of max tension
MAX. W	Max weight (tension) to be entered in selected display unit
CAL. W	Calibration weight to be entered in the selected calibration unit
FILT	The filter is selectable for analogue outputs "Ao1", "Ao2" and "Ao4", all in one, output "Ao3" has no filter. The filter is based on a sampling frequency of 1 KHz and the filter is the average reading of the selected number of samples.
Alarm level	Level in % of max. tension when the alarm is activated. Connected to output "D0" and has a pre-set value of 5%.
Alarm delay	Select the delay in seconds before "Alarm" is activated.

4.2 Menu Tree



4.3 Gain

The Advance Range AO8050 amplifier has a range of pre-set selectable gain settings as shown below.


G1	± 4.9V
G8	± 614mV
G16, SLC	± 306Mv (Half Bridge 120 Ohm)
G32	± 153mV
G64	± 76mV
G128, FLC	± 38mV (Full Bridge 350, 720, 1K Ohm)

It is important that the correct gain is selected before the calibration process is started, failure to do so may result in 'Err' being displayed after 'Calc in progress' when pressing 'E' for 'DO CAL'. This error is a result of the input mV reading from the transducers exceeding the selected gain value prior to the calculation.

4.4 Determining the Gain

In order to determine the gain the following process should be carried out:

1. Wire the amplifier supply and load cell channel input(s) correctly as per section 3.2 Transducer Half Bridge Wiring Configurations or 3.3 Transducer Full Bridge Wiring Configurations and allow the amplifier to power up.
2. Place the full load you require on the load cells (This can be done with known weights and straps following the correct web path of the load cell roller(s)).
3. Go to '**DIAG**' > '**LOADC.**' > Look at the mV value displayed, this is the raw mV input into the amplifier.
4. Your Gain setting must be higher than this mV setting.



4.5 Calibration Process

4.5.1 Type Selection (Gain)


With reference to section 4.4 Determining the Gain from the home screen go to **'SETUP' > 'LOADC.'** > **'TYPE'** and select the gain that applies.

4.5.2 Mode Selection (STD single channel or dual channel for TLR)

Go to **'SETUP' > 'LOADC.'** > **'MODE'** and ensure **'STD'** is selected, this configuration is for single channel amplifiers (A8050) or to use only a single channel of a dual channel amplifier variant (AO8051 or AO8052).

4.5.3 Tare the Load Cell Roller

Loosen or remove the web so no tension is applied to the Load cell roller and ensure the correct roller of the application is fitted to the transducers. Follow the procedure outlined below.



Load Cell calibration


SETUP			
LOADC.	LOADC.		
	TYPE	LCTYPE	
		SLC	
		FLC	FLC
		G1-G128	
	MODE	LCMODE	
		STD	STD
		TLR	
	TARE	LCTARE	
		DO TARE	Enter
	CAL	LCCAL.	
		UNIT	N
		MAX.W	100.0
		CAL.W	50.0
		DO CAL	Enter
	FILT	FILTER	1000
	ALARM	ALARM	
		LEVEL	0.0
		DELAY	0.0

4.5.4 Calibrate the Load Cell Roller

From the main menu go to **'SETUP' > 'LOADC.'** > **'CALC' > 'UNIT'** and select the engineering units the user requires for input and the display.

From the main menu go to **'SETUP' > 'LOADC.'** > **'CALC' > 'MAX. W'** and set the maximum web tension for the application.

From the main menu go to **'SETUP' > 'LOADC.'** > **'CALC' > 'CAL.W'** and apply 100% of the web tension to the web.



Thread a rope over the centre of the Load cell roller following the path of the web. Fasten one end of the rope and apply known weight to the other end.

Select **"Do Cal"** Press **"E"** to Calibrate the amplifier to the force on the load cell roller.

Menu system:

Use the [**M**, **E**, **▲** & **▼**] buttons on the front


Press and Hold **"M"** for 2 sec to abort change
Press **"E"** saves new value

Value: (750)

"▲" Increase

"▼" Decrease

"M" Move to left Digit



5. Technical Data

Individual Features	AO8050	AO8051	AO8052
Mini USB-port for programming	X	X	X
Modbus RTU/RS485	X	X	X
Total-Left-Right (TLR) load measurement		X	X
Modbus TCP/IP Ethernet			X

AO805(X) Technical Data

Supply

Power Supply Voltage 24VDC +/-15%

Inputs

Measure range +/-39mV to +/-4.96V
 Number of load cells Semiconductor 4x 120 Ohms (Half Bridge)
 Number of load cells Strain Gauge 4x 350 Ohms (Full Bridge)
 Load cells sensitivity +/-1mV/V to +/-100mV/V
 Conversion per second 1.000/s
 Response time 1ms

Outputs

Analogue Outputs 1x 0-10v (2x TLR), 1x +/-0-10v and 1x 4-20mA

Supply Voltage Outputs

Tension Transducers 5VDC

Temperature

Operating Range -20°...+60°C